



# ADA COMPLIANCE DIVISION

Metropolitan Government of Nashville & Davidson County

## RIGHT-OF-WAY ACCESSIBILITY REVIEW

### PROJECT INFORMATION

Department/Agency: \_\_\_\_\_ Date: \_\_\_\_\_

Project Name: \_\_\_\_\_ Project Number: \_\_\_\_\_

Inspected by: \_\_\_\_\_ Date: \_\_\_\_\_

### CONTACT INFORMATION

Project Manager: \_\_\_\_\_ Phone Number: \_\_\_\_\_

Fax Number: \_\_\_\_\_ Pager Number: \_\_\_\_\_

E-Mail: \_\_\_\_\_

- notation or (n/a), if not applicable.

### PROJECT SCOPING INFORMATION

New construction  
 Rehab  
 Work in the right-of-way

Work out of the right-of-way  
 Path of travel  
 Other \_\_\_\_\_



**Accessible – Site**

4.3	<input type="checkbox"/> YES	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Accessible route (minimum of 36" clearance).
	<input type="checkbox"/> Comment			
4.4.1	<input type="checkbox"/> YES	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Protruding/Overhanging Objects (objects may not reduce 36" accessible route, wall mounted 27" to 80" range w/4" allowed into route, freestanding (pole) 27" to 80" range w/12" allowed into route. Below 27" no length requirement).
	<input type="checkbox"/> Comment			
4.5.4	<input type="checkbox"/> YES	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Grates within the walking surface (spaces no larger than ½". If elongated they must be placed with the long dimension perpendicular to the direction of travel).
	<input type="checkbox"/> Comment			
	<input type="checkbox"/> YES	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Other.
	<input type="checkbox"/> Comment			
	Comments:			

### Curb Ramps

4.7.2	<input type="checkbox"/> YES <input type="checkbox"/> Comment	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Slope (maximum slope 1:12, maximum rise of any run is 30").
4.7.5	<input type="checkbox"/> YES <input type="checkbox"/> Comment	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Sides of Curb Ramps (flared side maximum slope 1:12, not to be included as path of travel).
	<input type="checkbox"/> YES <input type="checkbox"/> Comment	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Other.
	<input type="checkbox"/> YES <input type="checkbox"/> Comment	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Other.
	Comments:			

### Ramps

4.8.2	<input type="checkbox"/> YES <input type="checkbox"/> Comment	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Ramp Slope and Run (maximum slope 1:12, maximum rise of any run 30").
4.8.3	<input type="checkbox"/> YES <input type="checkbox"/> Comment	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Clear Width (minimum 36").
4.8.4	<input type="checkbox"/> YES <input type="checkbox"/> Comment	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Landings (minimum length 60", width is a minimum of the ramp run width leading to it, if change of direction a minimum 60"x60").
4.8.6	<input type="checkbox"/> YES <input type="checkbox"/> Comment	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Cross-Slope and Surfaces (cross-slope no greater than 1:48, surface shall be firm, stable and slip resistant.
	<input type="checkbox"/> YES <input type="checkbox"/> Comment	<input type="checkbox"/> NO	<input type="checkbox"/> N/A	Other.

	Comments:	

**50% - 75% Completion Field Review:**

**Date:** \_\_\_\_\_

**Inspector:** \_\_\_\_\_

<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A <input type="checkbox"/> Comment	Project conforms to plans and specifications.
Deficiencies noted.	

**95% Completion Field Review:**

**Date:** \_\_\_\_\_

**Inspector:** \_\_\_\_\_

<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A <input type="checkbox"/> Comment	Project conforms to plans and specifications.
Deficiencies noted.	