

DO NOT OPEN YOUR POOL UNTIL IT IS DEEMED SAFE AND COMPLIANT.

If the Health Department has closed a pool, it SHALL NOT be re-opened without the expressed approval of your health inspector.

POOL WATER CHEMISTRY STANDARDS

Cold Water Pools (85 degrees F, or less)

Chlorine

Ideal: 1.0 – 2.0 ppm

Required: 0.5 – 3.0 ppm

Less than 0.5 or greater than 3.0 ppm is a violation

Closure: 0 ppm or greater than 4.0 ppm

Bromine

Ideal: 2.0 – 3.0 ppm

Required: 0.8 – 3.0 ppm

Less than 0.8 or greater than 3.0 ppm is a violation

Closure: 0 ppm or greater than 4.0 ppm

Hot Water Pools (greater than 85 degrees F)

Chlorine

Ideal: 3.0ppm

Required: 2.0 – 4.0 ppm

Less than 2.0 or greater than 4.0 is a violation

Closure: 0 ppm or greater than 4.0 ppm

Bromine

Ideal: 3.0 ppm

Required: 2.0 – 4.0 ppm

Less than 2.0 or greater than 4.0 is a violation

Closure: 0 ppm or 5.0 ppm

pH All Pools

Ideal: 7.2 – 7.6

Required: 7.2 - 7.6

Less than 7.2 or greater than 7.6 is a violation

Closure: Less than 6.8 or greater than 8.0

Cynauric Acid (All pools - as applicable)

Ideal: 25 – 40 ppm

Required: less than 100 ppm

greater than 40 ppm is a violation

Closure: greater than 100 ppm

Chloramines (combined chlorine) (All Chlorinated Pools)

Ideal: 0 ppm

Required: Less than 0.2 ppm

Closure: Greater than 0.2 ppm

Temperature for Spas

Ideal: Less than or equal to 104 °F

Required: Less than or equal to 104 °F

Closure: Greater than 104 °F