

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**LIBRARY – EDGEHILL**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4524882	LIBRARY OFFICE	2011-06-30 @ 11:00 am	2011-07-05 @ 1:00 pm	7.6	2011-07-07
4524881	LIBRARY OFFICE	2011-06-30 @ 11:00 am	2011-07-05 @ 1:00 pm	7.6	2011-07-07
4524877	MAIN – 1	2011-06-30 @ 11:00 am	2011-07-05 @ 1:00 pm	7.5	2011-07-07
4524878	MAIN – 2	2011-06-30 @ 11:00 am	2011-07-05 @ 1:00 pm	6.6	2011-07-07
4524879	MEETING ROOM	2011-06-30 @ 11:00 am	2011-07-05 @ 1:00 pm	7.2	2011-07-07
4524880	STAFF AREA	2011-06-30 @ 11:00 am	2011-07-05 @ 1:00 pm	6.8	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**LIBRARY – INGLEWOOD**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4524884	AREA 1	2011-06-30 @ 11:00 am	2011-07-05 @ 12:00 pm	6.6	2011-07-07
4524885	AREA 2	2011-06-30 @ 11:00 am	2011-07-05 @ 12:00 pm	6.7	2011-07-07
4524887	AREA 3	2011-06-30 @ 11:00 am	2011-07-05 @ 12:00 pm	7.1	2011-07-07
4524886	AREA 3	2011-06-30 @ 11:00 am	2011-07-05 @ 12:00 pm	6.5	2011-07-07
4524888	MEETING ROOM	2011-06-30 @ 11:00 am	2011-07-05 @ 12:00 pm	5.6	2011-07-07
4524883	STAFF AREA	2011-06-30 @ 11:00 am	2011-07-05 @ 12:00 pm	6.3	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**LIBRARY – METRO ARCHIVE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4525055	ARMY RECORDS	2011-06-30 @ 12:00 pm	2011-07-06 @ 1:00 pm	7.4	2011-07-07
4525057	BRANCH MANAGER	2011-06-30 @ 12:00 pm	2011-07-06 @ 1:00 pm	6.5	2011-07-07
4525056	BRANCH MANAGER	2011-06-30 @ 12:00 pm	2011-07-06 @ 1:00 pm	5.9	2011-07-07
4525058	MEETING AREA	2011-06-30 @ 12:00 pm	2011-07-06 @ 1:00 pm	7.1	2011-07-07
4525054	PAST UNIFORMS	2011-06-30 @ 12:00 pm	2011-07-06 @ 1:00 pm	6.6	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**LIBRARY – RICHLAND**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4525060	BRANCH MANAGER	2011-06-30 @ 3:00 pm	2011-07-06 @ 1:00 pm	2.7	2011-07-07
4525059	BRANCH MANAGER	2011-06-30 @ 3:00 pm	2011-07-06 @ 1:00 pm	2.6	2011-07-07
4525061	CHILD UNDER Q	2011-06-30 @ 3:00 pm	2011-07-06 @ 1:00 pm	2.2	2011-07-07
4525063	SPANISH	2011-06-30 @ 3:00 pm	2011-07-06 @ 1:00 pm	2.8	2011-07-07
4525062	YOUNG ADULT	2011-06-30 @ 3:00 pm	2011-07-06 @ 1:00 pm	2.8	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498