

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**PUBIC WORKS – GARAGE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4525048	DICKEY LANE	2011-06-30 @ 11:00 am	2011-07-06 @ 11:00 am	0.5	2011-07-07
4525043	IT REPAIRS	2011-06-30 @ 10:00 am	2011-07-06 @ 11:00 am	< 0.3	2011-07-07
4525045	METER SHOP	2011-06-30 @ 10:00 am	2011-07-06 @ 11:00 am	< 0.3	2011-07-07
4525047	OFFICES – FAR LE	2011-06-30 @ 11:00 am	2011-07-06 @ 11:00 am	0.7	2011-07-07
4525046	SAFETY OFFICE	2011-06-30 @ 11:00 am	2011-07-06 @ 11:00 am	< 0.3	2011-07-07
4525044	SIGN SHOP	2011-06-30 @ 10:00 am	2011-07-06 @ 11:00 am	0.6	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PUBLIC WORKS – EAST SERVICE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4524876	KIMBERLY OFFICE	2011-06-30 @ 10:00 am	2011-07-05 @ 12:00 pm	1.5	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PUBLIC WORKS – ENGINEERING**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4525051	END OF HALL	2011-06-30 @ 11:00 am	2011-07-06 @ 11:00 am	1.0	2011-07-07
4525050	OFFICE THRU RECO	2011-06-30 @ 11:00 am	2011-07-06 @ 11:00 am	0.8	2011-07-07
4525049	PERMIT OFFICE	2011-06-30 @ 11:00 am	2011-07-06 @ 11:00 am	0.9	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PUBLIC WORKS – HEAVY FLEET**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4524795	RIGHT OFFICE 1	2011-06-30 @ 10:00 am	2011-07-05 @ 12:00 pm	0.5	2011-07-07
4524796	RIGHT OFFICE 2	2011-06-30 @ 10:00 am	2011-07-05 @ 12:00 pm	0.6	2011-07-07
4524797	RIGHT OFFICE 3	2011-06-30 @ 10:00 am	2011-07-05 @ 12:00 pm	< 0.3	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PUBLIC WORKS – OFFICE EAST**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4524800	ENTRY OFFICE	2011-06-30 @ 10:00 am	2011-07-05 @ 12:00 pm	< 0.3	2011-07-07
4524799	ENTRY OFFICE	2011-06-30 @ 10:00 am	2011-07-05 @ 12:00 pm	< 0.3	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PUBLIC WORKS – PARTS ROOM**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4524798	PARTS ROOM	2011-06-30 @ 10:00 am	2011-07-05 @ 12:00 pm	< 0.3	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PUBLIC WORKS – STAFF SERVICES**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4525030	BILLY LYNCH	2011-06-30 @ 10:00 am	2011-07-06 @ 10:00 am	1.1	2011-07-07
4525035	CALL CENTER	2011-06-30 @ 10:00 am	2011-07-06 @ 10:00 am	1.4	2011-07-07
4525029	CLAYTON HAND	2011-06-30 @ 10:00 am	2011-07-06 @ 10:00 am	1.1	2011-07-07
4525036	DAN PURSLEY	2011-06-30 @ 10:00 am	2011-07-06 @ 10:00 am	1.0	2011-07-07
4525032	HUMAN RESOURCES	2011-06-30 @ 10:00 am	2011-07-06 @ 10:00 am	1.2	2011-07-07
4525034	PAUL HILTZ	2011-06-30 @ 10:00 am	2011-07-06 @ 10:00 am	1.1	2011-07-07
4525033	PAUL HILTZ	2011-06-30 @ 10:00 am	2011-07-06 @ 10:00 am	1.1	2011-07-07
4525031	SHARON WHALSTROM	2011-06-30 @ 10:00 am	2011-07-06 @ 10:00 am	1.1	2011-07-07
4525028	VERONICA FRAZIER	2011-06-30 @ 10:00 am	2011-07-06 @ 10:00 am	1.1	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PUBLIC WORKS – STREET SERVICES**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4524794	KIMBERLY OFFICE	2011-06-30 @ 10:00 am	2011-07-05 @ 12:00 pm	1.3	2011-07-07
4524792	RIGHT HALL OFFIC	2011-06-30 @ 10:00 am	2011-07-05 @ 12:00 pm	1.2	2011-07-07
4524790	RIGHT HALL OFFIC	2011-06-30 @ 10:00 am	2011-07-05 @ 12:00 pm	1.0	2011-07-07
4524789	RIGHT HALL OFFIC	2011-06-30 @ 10:00 am	2011-07-05 @ 12:00 pm	0.9	2011-07-07
4524788	RIGHT HALL OFFIC	2011-06-30 @ 10:00 am	2011-07-05 @ 12:00 pm	1.2	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498



---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PUBLIC WORKS – TRAFFIC**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4525042	OFFICES	2011-06-30 @ 10:00 am	2011-07-06 @ 11:00 am	< 0.3	2011-07-07
4525041	RIGHT CUBES	2011-06-30 @ 10:00 am	2011-07-06 @ 11:00 am	< 0.3	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PUBLIC WORKS – WAREHOUSE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4525038	ENTRANCE	2011-06-30 @ 10:00 am	2011-07-06 @ 10:00 am	< 0.3	2011-07-07
4525037	OFFICE	2011-06-30 @ 10:00 am	2011-07-06 @ 10:00 am	0.6	2011-07-07
4525039	STORAGE RACK B	2011-06-30 @ 10:00 am	2011-07-06 @ 11:00 am	< 0.3	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PUBLIC WORKS – WASHRACKS**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4525040	CABIN	2011-06-30 @ 10:00 am	2011-07-06 @ 11:00 am	< 0.3	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

July 7, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PUBLIC WORKS – WEST GARAGE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4525053	MEETING AREA	2011-06-30 @ 11:00 am	2011-07-06 @ 1:00 pm	0.8	2011-07-07
4525052	MEETING AREA	2011-06-30 @ 11:00 am	2011-07-06 @ 1:00 pm	0.6	2011-07-07

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498