
October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
MWS – DRY CREEK

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4540532	ADMINISTRATION O	2011-10-21 @ 10:00 am	2011-10-24 @ 9:00 am	3.1	2011-10-25
4540531	ADMINISTRATION O	2011-10-21 @ 10:00 am	2011-10-24 @ 9:00 am	3.2	2011-10-25
4540533	DIGESTER BLDG OF	2011-10-21 @ 10:00 am	2011-10-24 @ 10:00 am	12.7	2011-10-25
4540534	FILTER BLDG CONT	2011-10-21 @ 10:00 am	2011-10-24 @ 10:00 am	1.3	2011-10-25
4540539	MAINT SHOP 2	2011-10-21 @ 11:00 am	2011-10-24 @ 9:00 am	2.1	2011-10-25
4540538	MAINT. SHOP 1	2011-10-21 @ 11:00 am	2011-10-24 @ 9:00 am	4.1	2011-10-25
4540537	MAINT. SHOP OFF.	2011-10-21 @ 11:00 am	2011-10-24 @ 9:00 am	4.8	2011-10-25
4540536	MAINT. SHOP OFF.	2011-10-21 @ 11:00 am	2011-10-24 @ 9:00 am	4.9	2011-10-25
4540535	OPER. CONTROL RO	2011-10-21 @ 10:00 am	2011-10-24 @ 9:00 am	2.3	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
MWS – K. R. HARRINGTON

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4540543	CONTROL ROOM	2011-10-21 @ 12:00 pm	2011-10-24 @ 10:00 am	1.0	2011-10-25
4540541	MAINT. BLDG	2011-10-21 @ 12:00 pm	2011-10-24 @ 10:00 am	1.5	2011-10-25
4540540	OFFICE	2011-10-21 @ 12:00 pm	2011-10-24 @ 10:00 am	2.2	2011-10-25
4540542	SW OFFICE	2011-10-21 @ 12:00 pm	2011-10-24 @ 10:00 am	1.4	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
MWS – OMOHUNDRO

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4540548	LAB	2011-10-21 @ 1:00 pm	2011-10-24 @ 12:00 pm	3.3	2011-10-25
4540544	MAIN OFFICE 1	2011-10-21 @ 1:00 pm	2011-10-24 @ 12:00 pm	9.3	2011-10-25
4540545	MAIN OFFICE 2	2011-10-21 @ 1:00 pm	2011-10-24 @ 12:00 pm	8.2	2011-10-25
4540549	MAINT. OFFICE GD	2011-10-21 @ 1:00 pm	2011-10-24 @ 1:00 pm	1.7	2011-10-25
4540550	MAINT. OFFICE TW	2011-10-21 @ 1:00 pm	2011-10-24 @ 12:00 pm	1.9	2011-10-25
4540547	PUMPSTATION PLAT	2011-10-21 @ 1:00 pm	2011-10-24 @ 12:00 pm	1.4	2011-10-25
4540546	SYSTEM CONTROL R	2011-10-21 @ 1:00 pm	2011-10-24 @ 12:00 pm	1.3	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
STORM WATER – BACK BAY

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4536596	999	2011-10-21 @ 10:00 am	2011-10-24 @ 9:00 am	< 0.3	2011-10-25
4536595	COMPUTER TRAININ	2011-10-21 @ 10:00 am	2011-10-24 @ 9:00 am	1.3	2011-10-25
4536594	OPEN OFFICE AREA	2011-10-21 @ 10:00 am	2011-10-24 @ 9:00 am	1.3	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

STORM WATER – FRONT OFFICE

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4536593	LAB	2011-10-21 @ 10:00 am	2011-10-24 @ 9:00 am	1.2	2011-10-25
4536591	MICHAEL HUNT	2011-10-21 @ 10:00 am	2011-10-24 @ 9:00 am	2.9	2011-10-25
4536590	OPEN OFFICE AREA	2011-10-21 @ 10:00 am	2011-10-24 @ 9:00 am	2.4	2011-10-25
4536592	WATERSHED	2011-10-21 @ 10:00 am	2011-10-24 @ 9:00 am	2.3	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

WATER – ADMINISTRATION BUILDING

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442457	105	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.9	2011-10-25
4442450	FRONT LOBBY	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.8	2011-10-25
4442452	JOBE	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.7	2011-10-25
4442455	LAB- HUGHES	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.6	2011-10-25
4442454	LAB- HUGHES	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.9	2011-10-25
4442456	LYNN	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.6	2011-10-25
4442451	SECURITY LOBBY	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.8	2011-10-25
4442453	TAYLOR	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.9	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
WATER – BIOSOLIDS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442490	101	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	0.6	2011-10-25
4442489	102	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	0.8	2011-10-25
4442491	109	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	0.6	2011-10-25
4442493	999	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	< 0.3	2011-10-25
4442492	BUD FOSTER	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	< 0.3	2011-10-25
4442488	LOBBY	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	0.5	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

WATER – CENTRAL – ADMIN BUILDING

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442459	101	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.8	2011-10-25
4442460	ELECTRICAL	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.9	2011-10-25
4442461	INSTRUMENT	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.9	2011-10-25
4442458	LOBBY	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	1.3	2011-10-25
4442462	MAINTENANCE CENT	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	1.3	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

WATER – CENTRAL –PROCESS CENTER

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442464	104	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.6	2011-10-25
4442463	110	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	0.8	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

WATER – CUSTOMER SERVICES CENTER

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442468	113	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	1.0	2011-10-25
4442467	190	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	1.1	2011-10-25
4442472	BILLING OFFICE	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	1.1	2011-10-25
4442471	BILLING OFFICE	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	1.0	2011-10-25
4442474	LOBBY	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	0.8	2011-10-25
4442473	LOBBY OFFICE	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	1.1	2011-10-25
4442469	METER READING	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	1.1	2011-10-25
4442470	METER SHOP	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	1.0	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

WATER – OCCUPATIONAL HEALTH

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442476	COWDEN OFFICE	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	12.1	2011-10-25
4442475	LOBBY	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	8.2	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
WATER – STORES

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442465	LOBBY	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	2.0	2011-10-25
4442466	OFFICE	2011-10-20 @ 10:00 am	2011-10-24 @ 9:00 am	2.2	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

Radon test result report for:**WATER – SYSTEM SERVICES BUILDING**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442484	102	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	4.3	2011-10-25
4442482	108	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	3.9	2011-10-25
4442483	111	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	4.2	2011-10-25
4442480	118	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	3.3	2011-10-25
4442481	119	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	3.2	2011-10-25
4442477	ANTHONY WAGNER	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	0.7	2011-10-25
4442486	CROSS CONNECTION	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	3.3	2011-10-25
4442485	CROSS CONNECTION	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	3.3	2011-10-25
4442487	FLEET	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	1.9	2011-10-25
4442479	GARY ROSETI	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	2.8	2011-10-25
4442478	GARY ROSETI	2011-10-20 @ 11:00 am	2011-10-24 @ 9:00 am	2.5	2011-10-25

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

WHITES CREEK ADMINISTRATIVE BUILDIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4536584	ELECTRIC SHOP	2011-10-21 @ 9:00 am	2011-10-24 @ 9:00 am	1.2	2011-10-25
4536585	ELECTRONICS	2011-10-21 @ 9:00 am	2011-10-24 @ 9:00 am	0.9	2011-10-25
4536583	ENV. COMPLIANCE	2011-10-21 @ 9:00 am	2011-10-24 @ 9:00 am	0.9	2011-10-25
4536582	ENV. COMPLIANCE	2011-10-21 @ 9:00 am	2011-10-24 @ 9:00 am	1.0	2011-10-25
4536578	PLANT MANAGER	2011-10-21 @ 9:00 am	2011-10-24 @ 9:00 am	1.1	2011-10-25
4536579	RECEPTIONIST	2011-10-21 @ 9:00 am	2011-10-24 @ 9:00 am	1.1	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

WHITES CREEK MAINTENANCE BUILDING

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4536586	SHOP	2011-10-21 @ 9:00 am	2011-10-24 @ 9:00 am	2.2	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 25, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

WHITES CREEK PROCESS CENTER

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4536588	BREAKROOM	2011-10-21 @ 9:00 am	2011-10-24 @ 9:00 am	2.0	2011-10-25
4536589	CONTROL ROOM	2011-10-21 @ 9:00 am	2011-10-24 @ 9:00 am	1.5	2011-10-25
4536587	LAB	2011-10-21 @ 9:00 am	2011-10-24 @ 9:00 am	1.7	2011-10-25

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498