
November 15, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

DRY CREEK

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4536597	DIGESTER OFFICE	2011-11-11 @ 11:00 am	2011-11-14 @ 10:00 am	7.7	2011-11-15
4442800	MAINT. SHOP	2011-11-11 @ 11:00 am	2011-11-14 @ 10:00 am	2.0	2011-11-15
4442799	MAINT. SHOP OFFI	2011-11-11 @ 11:00 am	2011-11-14 @ 10:00 am	2.7	2011-11-15
4442798	MAINT. SHOP OFFI	2011-11-11 @ 11:00 am	2011-11-14 @ 10:00 am	2.0	2011-11-15

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

November 15, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
OMOHUNDRO

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4536599	999	2011-11-11 @ 1:00 pm	2011-11-14 @ 11:00 am	< 0.3	2011-11-15
4536598	MAIN OFFICE 1	2011-11-11 @ 1:00 pm	2011-11-14 @ 11:00 am	3.0	2011-11-15
4536600	MAIN OFFICE 2	2011-11-11 @ 1:00 pm	2011-11-14 @ 11:00 am	2.4	2011-11-15

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

November 15, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

WATER – OCCUPATIONAL HEALTH

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442797	COWDEN OFFICE	2011-11-09 @ 8:00 am	2011-11-14 @ 11:00 am	6.3	2011-11-15
4442796	LOBBY	2011-11-09 @ 8:00 am	2011-11-14 @ 10:00 am	3.4	2011-11-15

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

November 15, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

WATER – SYSTEM SERVICES BUILDING

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442794	102	2011-11-09 @ 8:00 am	2011-11-14 @ 8:00 am	2.4	2011-11-15
4442795	111	2011-11-09 @ 8:00 am	2011-11-14 @ 9:00 am	3.0	2011-11-15

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498