

## Metro Water Services Buildings

	Page #
1. Storm Water A .....	<u>2</u>
2. Storm Water B .....	<u>3</u>
3. Omohundro Plant .....	<u>4</u>
4. Omohundro South .....	<u>5</u>
5. Dry Creek .....	<u>6&amp;7</u>
6. Storm Water Route Services .....	<u>8</u>
7. Whites Creek Admin .....	<u>9</u>
8. Whites Creek Maintenance .....	<u>10</u>
9. White Creek Process Center .....	<u>11</u>
10. Administration Building .....	<u>12</u>
11. Central Plant Warehouse .....	<u>13</u>
12. Maintenance Shop .....	<u>14</u>
13. Process Center .....	<u>15</u>
14. K.R. Harrington .....	<u>16</u>

---

April 12, 2016 **\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**STORMWATER A**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064886	LAB	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	< 0.3	2016-04-12
7064884	MICHEAL HUNT	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	1.1 ± 0.2	2016-04-12
7064885	OPEN OFFICE AREA	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	1.1 ± 0.3	2016-04-12
7064887	WATERSHED	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	0.7 ± 0.2	2016-04-12

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

April 12, 2016 **\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**STORMWATER B**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064888	OPEN OFFICE AREA	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	< 0.3	2016-04-12
7064889	ROLL CALL	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	< 0.3	2016-04-12

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

March 29, 2016  
**LABORATORY ANALYSIS  
REPORT \*\***

---

Radon test result report for:  
**WATER - OMOHUNDRO PLANT**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064873	CLAY HILL	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	< 0.3	2016-03-29
7064875	CONTROL ROOM	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	0.7 ± 0.2	2016-03-29
7064872	FRONT LOBBY	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	< 0.3	2016-03-29
7064876	LAB	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	0.8 ± 0.2	2016-03-29
7064877	LAB	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	1.0 ± 0.2	2016-03-29
7064878	PUMP STATION PLA	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	1.4 ± 0.3	2016-03-29
7064874	RANDY HUCKABEE	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	0.8 ± 0.2	2016-03-29

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

March 29, 2016 **\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**WATER - OMOHUNDRO SOUTH**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064861	A-104	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	0.7 ± 0.2	2016-03-29
7064864	A-119	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	0.7 ± 0.2	2016-03-29
7064865	A-121	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	< 0.3	2016-03-29
7064862	ALAN HAND	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	0.7 ± 0.2	2016-03-29
7064863	ANGIE FOSTER	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	0.9 ± 0.2	2016-03-29
7064868	B-152	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	< 0.3	2016-03-29
7064870	C-122	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	1.1 ± 0.3	2016-03-29
7064869	C-132	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	0.8 ± 0.2	2016-03-29
7064866	CONFERENCE ROOM	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	1.6 ± 0.3	2016-03-29
7064871	D-112	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	1.6 ± 0.3	2016-03-29
7064867	GALLERY ROOM	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	< 0.3	2016-03-29

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

**I2356 / ROAA YOUSIF**

<b>Kit Number</b>	<b>Start Date</b>	<b>Start Time</b>	<b>End Date</b>	<b>End Time</b>	<b>Temp.</b>	<b>Facility</b>	<b>Building</b>	<b>Room</b>	<b>Project ID</b>	<b>Floor</b>	<b>Result</b>
7064789	2016-04-15	1:00 pm	2016-04-18	9:00 am	78	WATER - DRY CREEK		ADMIN OFFICE		3	2.9
7064790	2016-04-15	1:00 pm	2016-04-18	9:00 am	76	WATER - DRY CREEK		MAINTENANCE OFFI		3	4.4
7064791	2016-04-15	1:00 pm	2016-04-18	9:00 am	78	WATER - DRY CREEK		MAINTENANCE OFFI		3	3.3
7064792	2016-04-15	1:00 pm	2016-04-18	9:00 am	71	WATER - DRY CREEK		MAINTENANCE SHOP		3	1.4
7064793	2016-04-15	1:00 pm	2016-04-18	9:00 am	74	WATER - DRY CREEK		MAINTENANCE SHOP		3	1.5
7064794	2016-04-15	1:00 pm	2016-04-18	9:00 am	74	WATER - DRY CREEK		FILTER CONTROL R		3	0.8
7064795	2016-04-15	1:00 pm	2016-04-18	9:00 am	70	WATER - DRY CREEK		OPER. CONTROL LA		3	0.8
7064796	2016-04-15	1:00 pm	2016-04-18	9:00 am	73	WATER - DRY CREEK		OPER. CONTROL OF		3	< 0.3
7064797	2016-04-15	1:00 pm	2016-04-18	9:00 am	70	WATER - DRY CREEK		DIGESTER OFFICE		3	2.3

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

May\*\* **LABORATORY ANALYSIS**  
3,  
2016 **REPORT \*\***

---

Radon test result report for:  
**WATER - DRY CREEK**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064798	MAINTENANCE OFFF	2016-04-29 @ 10:00 am	2016-05-02 @ 8:00 am	3.8 ± 0.5	2016-05-03

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

April 12, 2016 **\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**STORMWATER ROUTE SERVICES**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064891	DANNY ANKENBAUER	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	0.6 ± 0.2	2016-04-12
7064892	DAVID ERVIN	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	1.0 ± 0.2	2016-04-12
7064890	FRONT OFFICE	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	1.0 ± 0.2	2016-04-12
7064894	RANDY ARMOR	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	0.8 ± 0.2	2016-04-12
7064895	ROLL CALL	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	0.7 ± 0.2	2016-04-12

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498



---

April\*\* **LABORATORY ANALYSIS**  
12,  
2016 **REPORT \*\***

---

Radon test result report for:  
**WATER - WHITES CREEK ADMIN**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064785	ELECTRICAL	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	< 0.3	2016-04-12
7064900	ELECTRONICS	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	< 0.3	2016-04-12
7064898	ENV. COMPLIANCE	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	< 0.3	2016-04-12
7064896	MANAGER	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	< 0.3	2016-04-12
7064897	MANAGER	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	< 0.3	2016-04-12

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

April 12, 2016 **\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**WATER - WHITES CREEK MAINTENANCE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064899	SHOP	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	0.9 ± 0.2	2016-04-12

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

April 12, 2016 **\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**WATER - WHITES CREEK PROCESS CENTER**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064788	99999	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	< 0.3	2016-04-12
7064787	CONTROL ROOM	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	< 0.3	2016-04-12
7064786	LAB	2016-04-08 @ 1:00 pm	2016-04-11 @ 9:00 am	< 0.3	2016-04-12

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

Radon test result report for:

**MWS - ADMINISTRATION BUILDING**

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064850	105	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	< 0.3	2016-03-16
7064849	INSTRUMENTATION	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	0.6 ± 0.2	2016-03-16
7064846	JOBE OFFICE	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	< 0.3	2016-03-16
7064847	LAB	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	0.7 ± 0.2	2016-03-16
7064848	LAB 114	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	0.6 ± 0.2	2016-03-16
7064845	LOBBY	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	< 0.3	2016-03-16

Radon test result report for:

**MWS - CENTRAL PLANT WAREHOUSE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064859	LOBBY	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	< 0.3	2016-03-16
7064860	OFFICE	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	0.7 ± 0.2	2016-03-16

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

Radon test result report for:

**MWS - MAINTENANCE SHOP**

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064858	101	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	< 0.3	2016-03-16
7064854	ELECTRICAL	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	< 0.3	2016-03-16
7064853	INSTRUMENT SHOP	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	0.6 ± 0.2	2016-03-16
7064857	LOBBY	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	0.6 ± 0.2	2016-03-16
7064855	MAINTENANCE CENT	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	< 0.3	2016-03-16
7064856	MAINTENANCE CENT	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	0.6 ± 0.2	2016-03-16

---

August 22, 2017

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MWS - PROCESS CENTER**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
7064851	104	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	< 0.3	2016-03-16
7064852	110	2016-03-11 @ 1:00 pm	2016-03-14 @ 9:00 am	< 0.3	2016-03-16

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

March 29, 2016 **LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**WATER - K.R. HARRINGTON**

---

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7064883	99999	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	< 0.3	2016-03-29
7064880	CONFERENCE ROOM	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	1.3 ± 0.2	2016-03-29
7064882	CONTROL ROOM	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	< 0.3	2016-03-29
7064879	MAIN OFFICE	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	0.6 ± 0.2	2016-03-29
7064881	MAINTENANCE BLDG	2016-03-25 @ 1:00 pm	2016-03-28 @ 9:00 am	1.2 ± 0.2	2016-03-29

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498