

KARL F. DEAN  
MAYOR



## METROPOLITAN GOVERNMENT OF NASHVILLE AND DAVIDSON COUNTY

DEPARTMENT OF WATER AND SEWERAGE SERVICES  
STORMWATER DIVISION  
DEVELOPMENT REVIEW  
800 2ND AVENUE, SOUTH  
NASHVILLE, TENNESSEE 37210

June 6, 2013

Marc Lelong  
Eastern Regional Engineer  
KriStar Enterprises, Inc.  
18332 Invergordon Lane  
Cornelius, NC 28031

RE: Metro Water Services Proprietary BMP Approval  
FloGard Perk Filter by Kristar Enterprises

Dear Mr. Lelong,

Metro Water Services (MWS) is in the process of updating our approved listing of proprietary BMPs for use in Metropolitan Nashville and Davidson County, Tennessee (Metro). The Stormwater Management Manual, Volume 1 – Regulations Section 7.6 allows for the use of proprietary BMPs as Limited Application BMPs. Proprietary devices must be approved by MWS before they can be considered for use in Metro through an application and acceptance process. MWS has adopted an interim policy which includes the following:

*MWS will also accept current proprietary BMP certifications from the New Jersey Department of Environmental Protection (NJDEP). MWS will consider the results of other verification systems and review them on a case by case basis.*

Since the FloGard Perk Filter has not yet been evaluated or certified by NJDEP, the application submitted will be evaluated for compliance with the Technology Assessment Protocol –Ecology (TAPE) as defined by the Washington State Department of Ecology.

Based on the Washington State Department of Ecology's General Use Level Designation for Basic and Phosphorus Treatment for Kristar Enterprises, Inc. **FloGard Perk Filter (using ZPC Filter Media), has been approved for use in Metro as a treatment unit with an 80% TSS removal rate, provided that the project design is consistent with the following conditions:**

1. The model selected for the project design must be sized in accordance with the following table and based on the peak flow of the Metro water quality design storm as specified in Volume 1 – Regulations Section 7.6.2.

$$Q_p = C \cdot I \cdot A$$

Where:

$Q_p$  = the peak flow through the proprietary BMP in cfs (Water Quality Treatment Flow)

$C$  = runoff coefficient

$I$  = rainfall intensity, 2.45 inches/hour for Metro

$A$  = the contributing drainage area for the BMP, in acres

2. The peak inflow of the Water Quality Treatment Flow is limited to 1.5 gpm/ft<sup>2</sup> and the maximum inflow drainage area is limited to the impervious acres shown below.

Cartridge Height (in)	12	18	24	30
Water Quality Treatment Flow (gpm)	6.8	10.2	13.6	17
Maximum allowable inflow Area (acres)	0.25	0.38	0.49	0.62

3. Kristar must ensure all system designs conform to MWS Stormwater Regulations.
4. The design engineer (a Tennessee Professional Engineer) must approve the shop drawings for conformance to dimensions and design features. These approved shop drawings are to be submitted to MWS as part of the grading permit application. As-built certification of the units by a Tennessee Professional Engineer will be required prior to issuance of the Use and Occupancy Permit to the owner.
5. The maintenance plan for sites using this device shall incorporate, at a minimum, the manufacturer's recommended maintenance which must be submitted for approval by MWS.
6. MWS reserves the right to recall approvals for reasons including, but not limited to: 1) restrictions placed by the Tennessee Department of Environment and Conservation, 2) product modifications or system failures indicating questionable performance capability, 3) changes in MWS stormwater regulations or policy, or 4) changes in the Technology Acceptance Reciprocity Partnership (TARP) or NJDEP protocols.
7. MWS approvals based on Washington State Department of Ecology General Use Level Designation will run with the certification dates and deadlines defined by the Department of Ecology. If at any time the manufacturer submits an application to NJCAT and/or NJDEP, the manufacturer must notify MWS of the status of the application. MWS reserves the right to modify the certification based on the status of the application with NJCAT and/or NJDEP.


Marc Lelong  
June 6, 2013  
Perk Filter  
Page 3 of 3

As a condition of this approval, Kristar must submit for approval the following information no later than **July 12, 2013**. Submit the following information in electronic format for review and distribution (such as PDF, TIF, JPEG, Word, Excel).

- The manufacturer recommended maintenance plan which contains, at a minimum, the requirements included in the Proprietary BMP Inspections and Maintenance Checklist, attached.
- Design worksheet providing the following information:
  - a. Manufacturer and treatment device
  - b. Site specific information (total contributing drainage area, total contributing impervious drainage area, runoff coefficient)
  - c. Design data (cartridge/filter flow rate, water quality treatment flow required)
  - d. Calculations (show sizing for flow rate and maximum impervious area)
  - e. Selected model and parameters
  - f. Bypass flow and configuration
  - g. Details
  - h. Other relevant information specific to the treatment device

Additional information regarding the Stormwater Management Regulations may be found at [www.nashville.gov](http://www.nashville.gov). If you have any questions regarding the above information, please contact Laura Jones with Stormwater Development Review by phone, 615-880-3832, or email, [laura.jones2@nashville.gov](mailto:laura.jones2@nashville.gov).

Sincerely,



Roger D. Lindsey, P.E., CFM  
Program Manager - Development Review Section  
Metro Water Services - Stormwater Division  
800 2nd Ave South  
P.O. Box 196300  
Nashville, TN 37219-6300  
Phone: 615-862-4706  
Fax: 615-862-4715

L TJ