



Storm Water Division

Operating Policies

Routine Maintenance (RoM)



Policy No.: RoM-5	Page <u> 1 </u> of <u> 1 </u>
Subject: Pipe Materials	Effective Date: 10-01-12
Applies To: Stormwater Maintenance	<input type="checkbox"/> New Issue <input checked="" type="checkbox"/> Partial Revision <input type="checkbox"/> Complete Revision
Purpose: To define acceptable pipe materials and uses of each material type.	
Policy: <ol style="list-style-type: none"> 1. Pipes installed under public roadways will be reinforced concrete pipe (RCP) unless physical constraints at the site necessitate the use of corrugated metal pipe (CMP). 2. Driveway pipes and other pipes installed within a public right-of-way, but not under a public roadway, will be manufactured of either reinforced concrete pipe (RCP) or corrugated metal pipe (CMP). 3. The minimum diameter for a driveway pipe is 15 inches and the minimum diameter for a cross drain is 18 inches. 4. Plastic stormwater drainage pipe may not be installed within the public right-of-way, but may otherwise be installed on private property (installed by the property owner with permission from MWS) to convey stormwater runoff originating from private property. No conveyance system conveying stormwater runoff from the public right-of-way may be constructed of plastic pipe. Pipes on private property shall be the responsibility of the current property owner to maintain. 	
Revision No.: <u> 2 </u>	Recommended by:  Date <u> 11/14/16 </u> Assistant Director, Stormwater
Revision Date: 10/01/16	Approved by:  Date <u> 14 Nov 16 </u> Director of Metro Water Services

