

Guidelines for Water Tap Inspections-3/4" – 1"

The following guidelines for residential water tap inspections have been developed to assure accurate inspections.

Check for leaks on RTC.

Verify all fittings are brass or copper

Verify 12-18 inches of copper loop at RTC coming off main

Verify one (1) foot of gravel cover over line before backfill. If going under drive or road, must have two (2) feet of gravel cover over line before backfill. **If state highway or multi-lane road, must encase copper in PVC for protection, then put the 2 feet of gravel cover over line

Verify line three (3) feet deep or as low as the main if possible

Obtain chlorine residual reading and reading of 1.00 to 2.00