

Nashville 1

For Year - 2014

Inorganic Parameters

Results in mg/L unless noted

<u>Parameter</u>	<u>Metro Water Services</u>	<u>MCL</u>
Antimony - total	waived	0.006
Arsenic	waived	0.05
Asbestos *	not detected	7 million fibers / L
Barium	waived	2
Beryllium - total	waived	0.004
Cadmium	waived	0.005
Chromium	waived	0.1
Cyanide	waived	0.2
Fluoride	waived	4
Lead	<0.001	0.015 (action level)
Mercury	waived	0.002
Nickel	waived	0.1
Nitrate	0.48	10
Nitrite	<0.01	1
Selenium	waived	0.05
Thallium - total	waived	0.002

* Analyzed 2011

Secondary Standards

Results in mg/L unless noted

<u>Parameter</u>	<u>Metro Water Services</u>	<u>MCL</u>
Chloride	waived	250
Color	waived	15 (Color Units)
Copper	waived	1.3 (action level)
MBAS	waived	0.5
Iron	waived	0.3
Manganese	waived	0.05
Sulfate	waived	250
Total Dissolved Solids	waived	500
Zinc	waived	5
Odor (Threshold odor #)	waived	3 (TON)
pH	waived	6.5 to 8.5 (Std Units)
Silver	waived	0.1
Aluminum	waived	0.2

Trihalomethane

Results in µg/L unless noted

<u>Parameter</u>	<u>Metro Water Services</u>	<u>MCL</u>
Trichloromethane	31.1	N/A
Bromodichloromethane	5.1	N/A
Dibromochloromethane	1.10	N/A
Tribromomethane	<0.1	N/A
Total Trihalomethanes (THM's)	37.30	80

Haloacetic Acids

Results in µg/L unless noted

<u>Parameter</u>	<u>Metro Water Services</u>	<u>MCL</u>
Monochloroacetic Acid	<2	N/A
Dichloroacetic Acid	17.30	N/A
Trichloroacetic Acid	18.90	N/A
Monobromoacetic Acid	<2	N/A
Dibromoacetic Acid	1.35	N/A
Total Haloacetic Acids (HAA's)	37.55	60

Organic Parameters

Results in mg/L unless noted

Regulated Pesticides

<u>Parameter</u>	<u>Metro Water Services</u>	<u>MCL</u>
**Atrazine	not detected	0.003

Organic Parameters

Results in mg/L unless noted

Regulated Herbicides

<u>Parameter</u>	<u>Metro Water Services</u>	<u>MCL</u>
**Simazine	not detected	0.004

**Analyzed 4/17/12

Radiochemical Parameters

Analyzed November 2006

<u>Parameter</u>	<u>Metro Water Services</u>	<u>MCL</u>
Gross Alpha	<3.0 pci/L	15 pci / L
Radium - 226 / 228	<0.46 / 1.01 pci/L	3 / 5 pci / L

Miscellaneous

Results in mg/L unless noted

<u>Parameter</u>	<u>Metro Water Services</u>	<u>MCL</u>
Sodium	5.0	not established
Hardness (Calcium)	74	not established
Alkalinity	63	not established
Temperature	19.9	not established
Langlier Index	-1.2	not established
Aggressive Index	10.6	not established

Results in mg/L unless noted

Volatile Organic Chemicals

Analyzed 09/03/14

Regulated

Parameter

MCL

Benzene	not detected	0.005
Carbon Tetrachloride	not detected	0.005
Para - Dichlorobenzene	not detected	0.075
1,2 - Dichloroethane	not detected	0.005
1,1 - Dichloroethylene	not detected	0.007
1,1,1 - Trichloroethane	not detected	0.20
Trichloroethylene	not detected	0.005
Vinyl Chloride	not detected	0.002
cis -1,2 - Dichloroethylene	not detected	0.07
Dichloromethane	not detected	0.005
1,2 - Dichloropropane	not detected	0.005
Ethylbenzene	not detected	0.7
Monochlorobenzene	not detected	0.1
o - Dichlorobenzene	not detected	0.6
Styrene	not detected	0.1
Tetrachloroethylene	not detected	0.005
Toluene	not detected	1
trans - 1,2 - Dichloroethylene	not detected	0.1
Xylenes (total)	not detected	10
1,2,4 - Trichlorobenzene	not detected	0.07
1,1,2 - Trichloroethane	not detected	0.005

Results in mg/L unless noted

Volatile Organic Chemicals

Analyzed 09/03/14

Unregulated

Parameter

MCL

Bromobenzene	not detected	none
Bromodichloromethane	0.0038	none
Bromoform	not detected	none
Bromomethane	not detected	none
Chlorodibromomethane	0.0003	none
Chloroethane	not detected	none
Chloroform	0.013	none
Chloromethane	not detected	none
o - Chlorotoluene	not detected	none
p - Chlorotoluene	not detected	none
Dibromomethane	not detected	none
m - Dichlorobenzene	not detected	none
1,1 - Dichloroethane	not detected	none
1,3 - Dichloropropane	not detected	none
2,2 - Dichloropropane	not detected	none
1,1 - Dichloropropene	not detected	none
1,3 - Dichloropropene	not detected	none
1,1,1,2 - Tetrachloroethane	not detected	none
1,1,2,2 - Tetrachloroethane	not detected	none
1,2,3 - Trichloropropane	not detected	none