



AGENDA

*The Metropolitan Government of Nashville and Davidson County...*

*Board of Electrical Examiners and Appeals  
AGENDA*

Meeting Date: Tuesday – April 23, 2019  
 Place: Metro Office Building – 800 2<sup>nd</sup> Avenue, South  
 Second Floor in the Davidson Room  
 Time: 1:30 P.M.

BOARD MEMBERS	TERM EXPIRES	ATTENDANCE	STAFF PRESENT
R. Michael Williams, Chairman Robert Cohen Thomas Greer Scott Newell Mark Poole Wayne Settles Pamela Wyatt Terry Atwood Justin deGraauw	February 15, 2020 April 15, 2021 February 15, 2023 April 16, 2020 February 2, 2020 October 19, 2019 October 19, 2019 June 20, 2021 February 15, 2023		

AGENDA TOPICS

- I. Approval of Last Month's Minutes and Call Meeting To Order
- II. Appeal Cases
- III. Appearing before the Board
- IV. Property Owner Permits
- V. Examination Approval
- VI. Examination Grade Approval
- VII. Registration Approval
- VIII. Other Business Old and New
- IX. Consent Agenda
- X. Adjournment

**APPEAL OF DECISIONS FROM THE BOARD OF ELECTRICAL EXAMINERS**

Pursuant to the provisions of § 2.68.030 of the Metropolitan Code of Laws, please take notice that decisions of the Metropolitan Board of Electrical Examiners and Appeals may be appealed to the Chancery Court or Circuit Court of Davidson County for review under a common law writ of certiorari. Any appeal must be filed within sixty (60) days after entry of a final decision by the Board. Any person or other entity considering an appeal should consult with an attorney to ensure that time and procedural requirements are met.

I. APPROVAL OF MINUTES AND CALL THE MEETING TO ORDER

Approval of the March 26, 2019 Minutes.

Changes:

Approval By:

Signature of Chairman \_\_\_\_\_

Motion:

First:

Second:

Opposed:

## II. APPEAL CASES

**Appeal Case No. 2019- 0021460**

Represented by: Brandon Bell

Site Address: 600 Broadway, 901-913  
 Map/Parcel Number: 093063A00200CO  
 Appellant: Gresham Smith

Code Provision: 2011 NEC 210.52(D) Bathrooms. In dwelling units, at least one receptacle outlet shall be installed in bathrooms within 3ft of the outside edge of each basin. The receptacle outlet shall be located on a wall or partition that is adjacent to the basin or basin countertop, located on the countertop, or installed on the side or face of the basin cabinet not more than 12in below the countertop. Receptacle outlet assemblies listed for the application shall be permitted to be installed in the countertop.

Variance Requested: Applicant is appealing receptacle requirement due to unique bathroom layout.

Discussion: This is a 34 story high rise residential tower.

Motion:

Opposed or Abstained:

First:  
Second:

## IV. PROPERTY OWNER PERMITS

No Business At This Time

## V. EXAMINATION APPROVAL

No Business At This Time

## VI. EXAMINATION GRADE APPROVAL

No Business At This Time

## VII. REGISTRATION APPROVAL

No Business At This Time

## VIII. OTHER BUSINESS OLD AND NEW

No Business At This Time

IX. CONSENT AGENDA

No Business At This Time

VI. MOTION FOR ADJOURNMENT:

Motion:  
First:  
Second:

Opposed or Abstained: