



- VAULT NOTES:**
- (A) 4000 P.S.I. CONCRETE SHALL BE USED.
 - (B) CONCRETE SIDEWALLS TO BE REINFORCED WITH #3 REBAR CENTERED EACH WAY.
 - (C) CORE FOR PIPE TO HAVE A-LOK SEAL INSTALLED OR APPROVED EQUAL.

NOTES:

DOMESTIC METERED WATER SERVICE LINE TO BE TYPE "K" COPPER WITH COMPRESSION OR FLARED FITTINGS IN METER VAULT. COPPER SERVICE LINE TO EXTEND 36" BEYOND METER BOX.

IDENTIFICATION (ID) METAL TAG WITH THE ADDRESS NUMBER SHALL BE WIRED AROUND EACH LINE.

METER BOX MAY BE ENLARGED TO ALLOW FOR ADDITIONAL METERS.

METRO WATER SERVICES

3" MANIFOLD FOR 3/4" AND/OR 1" MULTI SERVICES IN VAULT

NOT TO SCALE | DATE: 03/18/15

DWG. NO. WDET002J



Hal Balthrop
LICENSED DISTRIBUTION OPERATOR

8/1/15

DIRECTOR OF WATER AND SEWERAGE SERVICES