



NOTES:

- RADIO READ UNIT TO BE INSTALLED ON SERVICE LINES AS INDICATED BY METRO WATER SERVICE PERMIT OFFICE.
- REFERENCE DETAIL AS REQUIRED FOR RADIO READ UNIT LOCATION IN FRAME AND COVER. ONLY ONE FRAME AND COVER MAYBE REQUIRED RADIO READ READY.
- DISTANCE FROM TOP OF METER TO COVER TO BE MAX. 24"
- CONCRETE: 4500 PSI @ 28 DAYS REINFORCED WITH #4 BARS
- ALL NIPPLES TO BE BRASS OR DUCTILE IRON.
- RADIO READ UNIT TO BE INSTALLED AS PER MANUFACTURES SPECIFICATIONS.

METRO WATER SERVICES

1-1/2" OR 2" BATTERY ON
3" OR 4" SERVICE

NOT TO SCALE DATE: 05/05/08

DWG. NO. WDET018E



Hal Balthrop
LICENSED DISTRIBUTION OPERATOR

SNitt
DIRECTOR OF WATER AND SEWERAGE SERVICES