



**NOTES:**

FLUSHING VALVE WILL BE REQUIRED WHEN DISTANCE BETWEEN TEE AND DDCVA IS GREATER THAN 20 FEET.

FLUSHING VALVE MUST BE NO MORE THAN 5 FEET IN FRONT OF DDCVA.

FLUSHING TIMER TO BE RAINBIRD OR EQUAL PROGRAMMABLE TIMER.

TIMER PROGRAM TO BE 3-DAY CYCLE WITH A MINIMUM OF 11 SECONDS ON.

BACKFLOW NOT REQUIRED ON FLUSING VALVE LINE DUE TO CHECK VALVE IN METER ASSEMBLY

**METRO WATER SERVICES**

**FLUSHING VALVE FOR  
FIRE SERVICE**

NOT TO SCALE DATE: 9/14/17

DWG. NO. SHEMATIC 12



*Glenn S. Scott*  
LICENSED DISTRIBUTION OPERATOR

*Scott*  
DIRECTOR OF WATER AND SEWERAGE SERVICES