


PLAN

METRO WATER SERVICE APPROVED MATERIALS
USE 1" CONCRETE METER BOX AND TRAFFIC
FRAME & COVER (JBS # 8122) MARKED
"SEWER". (OR APPROVED EQUAL)

MINIMUM COVER FOR LINES
18" OUTSIDE ROADWAY
30" INSIDE ROADWAY

CLEAN OUTS
(USE STANDARD WYE
FITTINGS WITH THREADED
PLUGS OR CAP)



ELEVATION

METRO WATER SERVICES

GRINDER PUMP
SERVICE BOX AT R.O.W.

NOT TO SCALE DATE: 02/22/08

DWG. NO. GP-4

METRO
WATER SERVICES

Hal Baltthop

LICENSED COLLECTION OPERATOR

S. M. Nett

DIRECTOR OF WATER AND SEWERAGE SERVICES