



NO OPEN SAND CASTINGS, CASTINGS ARE TO BE MADE OF CAST IRON IN ACCORDANCE WITH CURRENT SPECIFICATIONS. COVER MUST FIT EVENLY ON RABBIT OF FRAME IN ORDER TO EQUALLY DISTRIBUTE WIEGT OF COVER OVER FRAME MINIMUM WIEGT OF FRAME 150 LBS. MINIMUM WIEGT OF COVER 45 LBS.

TO BE USED FOR SEWER INSPECTION ASSEMBLY

METRO WATER SERVICES
SEWER (SMALL SIZE) CAST IRON
VALVE BOX FRAME AND COVER

NOT TO SCALE | DATE: 02/22/08

DWG. NO. SDET020



Hal Balthrop
 LICENSED COLLECTION OPERATOR

J. N. Pitt
 DIRECTOR OF WATER AND SEWERAGE SERVICES