



TYPICAL CREEK CROSSING
FOR WATER MAINS

NOTES:

- CONCRETE TO BE CLASS "B" AS SPECIFIED IN CONTRACT DOCUMENT SECTION 03300.
- ENCASEMENT WIDTH TO BE POURED THE WIDTH OF TRENCH WITH A MINIMUM OF 4" ON EACH SIDE PIPE.

METRO WATER SERVICES

CREEK CROSSING
FOR WATER MAINS

NOT TO SCALE | DATE: 02/22/08

DWG. NO. WDET010B



Hal Balthrop
LICENSED DISTRIBUTION OPERATOR

S. Voth

DIRECTOR OF WATER AND SEWERAGE SERVICES